



Date: 10/24/2023

Project Name: Guaranteed Rate Field – Fire Alarm System Replacement Project

Project Number: 22096

Addendum No.: Addendum #2

New Due Date: Monday October 30, 2023 at 10:00 AM CT

This Addendum consists of additions and/or modifications to the plans and/or specifications to the contract documents. The changes to these documents are only in the manner and to the extent stated herein. All drawings have “Issued for Addendum #2” and “10.23.2023” in the title block. Changes are bubbled and tagged with revision Delta 2. This Addendum supersedes any oral or written information previously delivered.

- Clarifications
1. ~~Alterations~~ - 3 scope for remote annunciation indicator device on the outside of each electrical room shall be added if required by the local code. A remote annunciation indicator device shall be turned on upon activation of the electrical room smoke detector.
 2. There are plenum ceilings are present on the ground level. Therefore, provide Chicago approved conduit, fittings, backbox, and devices in the plenum ceiling.
 3. Project Completion date shall be 03/31/2025.

Drawing Revisions

E1.001	E1.204
E1.002	E1.206
E1.004	E1.304
E1.005	E1.306
E1.006	E1.308
E1.008	E1.309
E1.009	E1.404
E1.010	E1.406
E1.011	E1.409
E1.101	E1.504
E1.104	E1.506
E1.106	E1.509
E1.109	E1.601
E1.111	

END OF ADDENDUM