



Date: 10/18/2023

Project Name: Guaranteed Rate Field – Fire Alarm System Replacement Project

Project Number: 22096

Addendum No.: Addendum #1

This Addendum consists of additions and/or modifications to the plans and/or specifications to the contract documents. The changes to these documents are only in the manner and to the extent stated herein. All drawings have “Issued for Addendum #1” and “10.18.2023” in the title block. Changes are bubbled and tagged with revision Delta 1. This Addendum supersedes any oral or written information previously delivered.

Clarifications

1. A speaker in the elevator cab scope shall be completed by the GRF under a separate contract.
2. Emergency power to the existing PA amplifier systems shall be installed under a separate contract.
3. The dumpster shall be provided by the contractor.
4. Patch and paint as required shall be by the contractor. Coordinate with the GRF for the paint color and finishes.
5. Provide IP connection to the new fire alarm control panel as required by the city of Chicago fire department.

Specifications

22096 - 28 31 11_Digital, Addressable Fire-Alarm System

Drawing Revisions

1. E1.006
2. E1.010
3. E1.306
4. E1.601
5. E1.602
6. E1.603
7. E1.604
8. E1.605
9. E1.608
10. E2.001

END OF ADDENDUM