



Date: December 1, 2025

Project Name: Waste/Vent Piping FY2026

Project Number: 25081

Addendum No.: 1

This Addendum consists of additions and/or modifications to the plans and/or specifications to the contract documents. The changes to these documents are only in the manner and to the extent stated herein.

All drawings have “Issued for Addendum No. 1” and “11.26.2025” in the title block. Changes are bubbled and tagged with revision Delta 1.

Bid Form is also updated accordingly. Changes are in bold and have a solid black line at right margin identifying portions of the document that have been updated.

This Addendum supersedes any oral or written information previously delivered.

Revisions

1. G0.001 is updated:
 - a. *'Issue Title'* updated to 'Issued for Bid'.
 - b. Added TC faucet count per level.
2. P0.001 is updated:
 - a. Add abbreviations for ARW and ARV.
3. P1.U01 - P1.U11 were added:
 - a. Additional underground scoping identified.
 - b. Some sheets are 'For Reference Only'.
4. P1.S01 – P1.S11 were updated:
 - a. Keynote 1 updated throughout for lavatory faucets.
 - b. P1.S06 sanitary scope updated for Rate Field Kitchen grease waste; existing is incorrectly tied-into storm.
 - c. P1.S08 updated sump pump keyed note 2.
 - d. P1.S08 sump pump discharge piping scope added per comments regarding freezing conditions with current pump discharge pipe routing.
 - e. P1.S08 vertical sanitary stack lining added.
 - f. P1.S09 added cleanout on ARW piping and updated existing downstream piping size per existing field conditions.
 - g. P1.S10 updated sump pump keyed note 2.

Continued on next page.



5. P1.102 – P1.111 were updated:
 - a. Keynote 1 updated throughout for lavatory faucets.
 - b. Beer stand vent scope updated.
 - c. Lining beer stand deck drain body and downstream piping added.
 - d. P1.108 sanitary scope added.
 - e. P1.108 sanitary content removed.
6. P1.203 – P1.210 updated:
 - a. Keynote 1 updated throughout for lavatory faucets.
 - b. P1.206 keynote 2 grease trap construction updated.
 - c. P1.208 sanitary content removed.
7. P1.304 – P1.309 updated:
 - a. Keynote 1 updated throughout for lavatory faucets.
 - b. P1.304 domestic water scope moved to level 300 ceiling from level 400 ceiling.
8. P1.404 – P1.410 updated:
 - a. Keynote 1 updated throughout for lavatory faucets.
 - b. P1.404 domestic water scope moved from level 400 ceiling to level 300 ceiling.
 - c. P1.406 - P1.407 owner's suite bathrooms don't have TC faucets. Keynote removed from owner's suite bathrooms.
9. P1.503 – P1.510 updated:
 - a. Keynote 1 updated throughout for lavatory faucets.

Attachments

1. G0.001, P0.001, P1.U01-P1.U11, P1.S01-P1.S11, P1.02-P1.111, P1.203-P1.210, P1.304-P1.309, P1.404-P1.410, and P1.503-P1.510
2. Updated Bid Form.

END OF ADDENDUM